

# Louisiana State University Design Standards

## DIVISION 10 – SPECIALTIES

### 1 VISUAL DISPLAY SURFACES

- 1.1 Glass marker boards must be provided by a single manufacturer.
- 1.2 1/4" Tempered safety writing glass, polished with eased corners
- 1.3 Size of white marker board shall be 48 inches in height at all locations.
  - 1.3.1 Repair and preparation of existing wall surfaces to which these boards are to be attached and to make ready for the installation of this work is a requirement of this project.
- 1.4 All boards to be mechanically fastened to sound substrates.
- 1.5 The University prefers metal trim bulletin, chalk boards and erasable marker boards.
- 1.6 Standard heights for boards will be 37" above the floor to the tray.

### 2 BOARDS

- 2.1 The University prefers metal trim bulletin, chalk boards and erasable marker boards.
- 2.2 Standard heights for boards will be 37" above the floor to the tray.

### 3 RESTROOMS

- 3.1 The University prefers floor supported head rail braced toilet partitions.
  - 3.1.1 Do not use a ceiling hung partition unless enclosed on each side with a wall. Partitions and doors shall be solid phenolic resin core, solid plastic or solid color reinforced composite.
- 3.2 Partitions layout shall comply with ADA requirements. All hardware shall be type 304 stainless steel and door hinges shall be field adjustable to be self-closing or partially open when unoccupied.
- 3.3 Dispensers—Jumbo Bath Tissue Dispensers, Paper Towel Dispensers and Soap Dispensers will be furnished by The University and installed by the contractor as per ADA guidelines.
- 3.4 Jumbo (12") Bath Tissue Dispensers furnished by The University will be Georgia- Pacific 59012.
- 3.5 Paper Towel Dispensers furnished by the University will be Kimberly Clark 09990.
- 3.6 Soap Dispensers furnished by the University will be GOJO Industries 5271-06.
- 3.7 Mirrors shall be provided with a theft-proof locking device.

### 4 FIRE EXTINGUISHERS

- 4.1 Unless codes provide otherwise, the University prefers fire extinguishers rather than fire hoses. Fire extinguisher cabinets shall be provided in corridors only.
- 4.2 Fire extinguishers for general purpose shall be ABC multi-purpose, dry chemical.
- 4.3 Fire extinguishers for equipment rooms shall be CO2.
- 4.4 Cabinets shall be semi- recessed, lockable with break-glass doors.

### 5 FIXED SEATING FOR LECTURE WITH MULTIPLE SEATING

- 5.1 The Director of LSU's Office of Procurement Services has approved a proprietary specification for the purchase and installation of fixed, lecture seating in academic buildings.
  - 5.1.1 Acceptable Manufacturer - American Seating Company
  - 5.1.2 Product - Stellar - Model 3522 w/LSU custom tablet arm
  - 5.1.3 Color - To be approved by the University

### 6 INTERIOR / EXTERIOR ROOM SIGNAGE GUIDELINES

- 6.1 Refer to LSU Interior / Exterior Room and Building Signage Guidelines

### 7 SITE & LANDSCAPE IMPROVEMENTS

- 7.1 Refer to Campus Site & Landscape Standards & Guidelines

### 8 WAYFINDING IMPROVEMENTS

- 8.1 Refer to Wayfinding Guidelines with Addendum